

Miller ProHeat 35

Unit Serial Number: MD170244G

Date Tested: 8-4-15

Certified Calibration

Primary Standard						
	382° (F) 2.787VDC@RC9		882° (F) 6.013VDC@RC9		1382° (F) 9.239VDC@RC9	
	RC9 output DC voltage reading	ProHeat 35 display	RC9 output DC voltage reading	ProHeat 35 display	RC9 output DC voltage reading	ProHeat 35 display
TC1	2.784	382	6.012	882	9.240	1382
TC2	2.789	382	6.013	882	9.237	1382
TC3	2.781	382	6.011	882	9.236	1382
TC4	2.793	382	6.021	882	9.241	1382
TC5	2.788	382	6.012	882	9.238	1381
TC6	2.789	382	6.010	881	9.238	1381
Allowable	2.749-2.825	+/- 3° F	5.975-6.051	+/- 3° F	9.201-9.277	+/- 3° F

Instruments Used:

Fluke 714 Thermocouple Calibrator SN: 2969020 Calibration Date: 11-21-14

Precision Digital Voltage Meter SN: 3030025 Calibration Date: 1-23-15

Machine re-calibration due date: 8-4-16

Red-D-Arc does hereby certify the above instrument was calibrated against standards maintained by Red-D-Arc and meets or exceeds all published specifications. The accuracy of these standards is directly traceable to the National Institute of Standards and Technology.

Unit passed inspection.



Technician: chris nieters

Date: 8-4-15

Signature