

Red-D-Arc Welderrentals

Calibration Certificate

Unit Serial Number: IH-M040062

Date Tested: 9-1-15

Instrument Number: 51371

Mac Address: 00:0A:8D:00:C8:AB

IP Address: 192.168.111.222

Primary Standard						
	382 (F)		882 (F)		1382 (F)	
	Signal Voltage	Recorder display	Signal Voltage	Recorder display	Signal Voltage	Recorder display
Channel 1	2.792	383	6.012	882	9.228	1381
Channel 2	2.792	383	6.014	882	9.235	1382
Channel 3	2.787	382	6.011	882	9.237	1382
Channel 4	2.790	382	6.012	882	9.244	1383
Channel 5	2.793	383	6.014	882	9.248	1383
Channel 6	2.799	383	6.036	883	9.253	1383

Allowable difference in temp reading is +or- 5 Deg. F.

Instruments Used:

Fluke 714 Thermocouple Calibrator SN: 2969020

Calibration Date: 11-21-14

Precision digital multimeter SN: 303002

Calibration Date: 1-23-15

ProHeat 35 power supply used for signal output SN: MMC100327

Calibration date: 7-7-15

Red-D-Arc does hereby certify the above instrument was calibrated against standards maintained by Red-D-Arc and meets or exceeds all published specifications. The accuracy of these standards is directly traceable to the National Institute of Standards and Technology.

Unit passed inspection.

Technician: Jared Lamar

Calibration due date: 9-1-16

Signature