

Red-D-Arc Welderrentals

Calibration Certificate

Miller ProHeat 35

Unit Serial Number: MC090111G

Date Tested: 8/8/2016

Certified Calibration

Primary Standard						
	382° (F) 2.787VDC@RC9		882° (F) 6.013VDC@RC9		1382° (F) 9.239VDC@RC9	
	RC9 output DC voltage reading	ProHeat 35 display	RC9 output DC voltage reading	ProHeat 35 display	RC9 output DC voltage reading	ProHeat 35 display
TC1	2.800	383	6.025	883	9.243	1382
TC2	2.793	383	6.024	883	9.245	1383
TC3	2.795	383	6.024	883	9.246	1383
TC4	2.792	383	6.022	882	9.243	1382
TC5	2.785	382	6.002	882	9.227	1381
TC6	2.788	382	6.019	882	9.234	1381
Allowable	2.749-2.825	+/- 3° F	5.975-6.051	+/- 3° F	9.201-9.277	+/- 3° F

Instruments Used:

Fluke 714 Thermocouple Calibrator SN: 1882015

Calibration Date: 10/26/2015

Precision Digital Voltage Meter SN: 2036021

Calibration Date: 10/26/2015

Machine re-calibration due date: 8/8/2017

Red-D-Arc does hereby certify the above instrument was calibrated against standards maintained by Red-D-Arc and meets or exceeds all published specifications. The accuracy of these standards is directly traceable to the National Institute of Standards and Technology.

Unit passed inspection.



Technician: Scott T.

Date: 8/8/2016

Signature